



Technical Declaration

1. Declaration number	1227
2. Unique identification code of the product	FSA, FSAFU, FSAMF, SLFA, SLFK
3. Type	Flexible silencer
4. Product description	The products are used to lower the sound level in ventilation systems
5. Manufacturer	Lindab

Declaration		
ISO EN-7235:2003	Acoustics -- Laboratory measurement procedures for ducted silencers and air-terminal units -- Insertion loss, flow noise and total pressure loss	The insertion loss and pressure drop measured. Insertion loss presented in octave band.
EN 12237:2003	Ventilation for buildings. Ductwork. Strength and leakage of circular sheet metal ducts	Some of the products reach airtightness class D in a system. See Eurovent certification.
EN 15727:2010	Ventilation for buildings. Ducts and ductwork components, leakage classification and testing	The products reach airtightness class C or D as components. For specific tightness class visit www.lindab.com .
The insulation is protected to prevent fibers to enter the airstream		
The silencers do not contain any hazardous materials. For more information about the contents of the product download the building product declarations from www.lindab.com		
Lindab declares that the characteristics and performances of the products supplied are in conformity with those described in the data sheets at the edition current at the date of delivery. The data sheets can be found at www.lindab.com .		

Signed for and on behalf of the manufacturers by:

Authorised person:
Tuomas Veijalainen
Product Manager
2022-09-22 Farum, Denmark