



Technical Declaration

1. Declaration number	1226
2. Unique identification code of the product	BSLCU, BSLU, KVAPL, KVDP-90K, KVDP-90L, KVPDX, LRBCB, LRCA, LRCB, LRCBC, LRCEC, LRCFU, PVA, PVAP, PVD, PVDP, SDI, SDO, SLBGU, SLBU, SLCBU, SLCU, SLGPU, SLGU, SLTR, SLU, SLXU
3. Type	Circular silencer
4. Product description	The products are used to lower the sound level in ventilation systems
5. Manufacturer	Lindab

Declaration		
ISO EN-7235:2009	Acoustics -- Laboratory measurement procedures for ducted silencers and air-terminal units -- loss, flow noise and total pressure loss	The insertion loss, pressure drop and self-generated noise measured. The insertion loss and self-generated Insertion noise presented in octave band.
EN 12237:2003	Ventilation for buildings. Ductwork. Strength and of circular sheet metal ducts See Eurovent certification.	The products reach airtightness class D in a system. leakage
EN 15727:2010	for buildings. Ducts and ductwork components, leakage classification and testing	The products reach airtightness class C or D as Ventilation components. For specific tightness class visit www.lindab.com .
The insulation is protected to prevent fibers to enter the airstream		
The silencers do not contain any hazardous materials. For more information about the contents of the product download the building product declarations from www.lindab.com		

Lindab declares that the characteristics and performances of the products supplied are in conformity with those described in the technical catalogue at the edition current at the date of delivery. The technical catalogue can be found at www.lindab.com.

Signed for and on behalf of the manufacturers by:

Authorised person:
Tuomas Veijalainen
Product Manager
2022-04-04 Farum, Denmark

