

## Declaration of Performance No. 1391-CPR-2021/0045 1. Unique identification code of the product-type SDJR-S Smoke control damper that is used in smoke control systems, in single-compartment applications, up to 600°C. 3. Manufacturers ID 26718405 5. System/s of AVCP System 1 6a. Harmonised standard EN 12101-8:2011 6a. Notified body Notified body No. 1391 PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek 6b. European Assessment Document 1391-CPR-2021/0045 7. Declared performance/s See table below.

Essential characteristic	Requirement clauses in EN 12101-8	Findings	Conformity assessment
Nominal activation conditions/sensitivity	cl. 4.2.1.3	Closing / opening during the test at the right time	Conforms
Response delay (response time)	cl. 4.2.1.4	< 60 s	Conforms
Operational reliability	cl. 4.4.2.2	C <sub>mod</sub>	Conforms
Fire resistance – integrity	cl. 4.1.1 a)	E <sub>600</sub> 120 < 360 m <sup>3</sup> /(h.m <sup>2</sup> )	Conforms
Fire resistance – insulation	cl. 4.1.1 b)	For single compartment dampers it's not req.	N/A
Fire resistance – smoke leakage	cl. 4.1.1 c)	E <sub>600</sub> 120 S1500 <200 m <sup>3</sup> /(h.m <sup>2</sup> )	Conforms
Fire resistance – mechanical stability	cl. 4.1.1 d)	120 min	Conforms
Fire resistance – maintenance of cross-section	cl. 4.1.1 e)	120 min	Conforms
Fire resistance – high operational temperature	cl. 4.1.1 f)	NPD	NPD
Durability of response delay	cl. 4.4.2.1	< 60 s	Conforms
Durability of operational reliability	cl. 4.4.2.2	C <sub>mod</sub> < 120 S	Conforms

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the supplier by:

Authorised person:

Lindab Ventilation AB SE-269 82 Båstad Phone +46 431 850 00



